

# WSPCert Certificate

**No. BAC-0212-01**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2010. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The 4 BACnet Smart Actuators (B-SA)  
**CompactSmoke™ Smoke Panel**  
**WSC 310 P, WSC 320 P**  
**Comfort MotorController**  
**WCC 310 P, WCC 320 P**

with the software version:

**V1**

of

**WindowMaster A/S**

Skelstedet 13, 2950 Vedbæk, Denmark

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 14.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2016\_12498**.

The certificate is valid  
until 2017/04/01



2016/08/16

Date of initial certification

A handwritten signature in black ink, appearing to be "G. Weinmann".

Dipl.-Ing. G. Weinmann  
Head of Certification Body

## Annex to Certificate No. BAC-0212-01

The certification of the BACnet Implementations  
**WSC 310 P, WSC 320 P, WCC 310 P, WCC 320 P**  
of **WindowMaster A/S**

refers to the BACnet Interoperability Building Blocks (BIBBs)  
listed below. BIBBs other than listed are not part of the cer-  
tification.

BACnet Interoperability Building Blocks	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DS-COV-B	Data Sharing – COV – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B